

27 August 2014

F1 Palm Grove Business Park
13-15 Forrester St
Kingsgrove NSW 2208

Tridonic Australia Pty Ltd.

Attention: Phillip Lowe
Dear Sir / Madam,

APPROVAL OF PRESCRIBED EQUIPMENT

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria.

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact Jean Marie Ntahonkiriye on telephone (03) 9203 9700, or email jntahonkiriye@esv.vic.gov.au

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change of registered Address within 20 business days.

Yours faithfully

A handwritten signature in black ink, appearing to read "J. Ntahonkiriye".

DIRECTOR OF ENERGY SAFETY

Ref: ESV140618/00

Certificate Number: ESV140618/00

Certificate of Approval

This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

Registered Declarant: Tridonic Australia Pty Ltd.
F1 Palm Grove Business Park
13-15 Forrester St
Kingsgrove NSW 2208

Required Marking: ESV140618

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the required marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification must be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

ARTICLE DETAILS

Electrical Equipment:	Prescribed Power Supply or Charger Electronic Controlgear for LED modules _ Buit-in type
Relevant Standards:	AS/NZS IEC 61347.2.13:2013 ; AS/NZS 61347.1:2002
Expiry Date:	27/08/2019
Conditions of Approval:	



DATE OF APPROVAL: 27/08/2014

Page: (2/ 3)

Director of Energy Safety

Certificate Number: ESV140618/00



Approval details

Buit-in type "EM powerLED FX"

Model	EM powerLED BASIC FX 104 LP 80W 200V
Rated at	Input: 220-240V, 90 W, 50/60Hz Output: 50-230 V dc, 34.5-80 W, 150- 500 mA
Trade Name	TRIDONIC
Comments	

A handwritten signature in black ink, appearing to read "J. Flewson".