

26 October 2016

43-47 Newton Rd
Wetherill Park NSW 2164

Tridonic Australia Pty Ltd.

Dear Sir / Madam,

APPROVAL OF NON-PRESCRIBED EQUIPMENT

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact Jean Marie Ntahonkiriye on telephone (03) 9203 9700, or email jntahonkiriye@esv.vic.gov.au

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change of registered Address within 20 business days.

Yours sincerely



DIRECTOR OF ENERGY SAFETY

Ref: ESV150300/06

Certificate Number: ESV150300/06

Certificate of Compliance

This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

Registered Declarant: Tridonic Australia Pty Ltd.
43-47 Newton Rd
Wetherill Park NSW 2164

Authorised Marking: ESV150300


Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, may be clearly and indelibly marked with the marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification should be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

ARTICLE DETAILS

| | |
|-------------------------|---|
| Electrical Equipment: | Level 1 NP: Non-Prescribed constant current dimming LED driver for inbuilding |
| Relevant Standards: | AS/NZS IEC 61347.2.13:2006; AS/NZS 61347.1:2002 |
| Expiry Date: | 13 May 2020 |
| Conditions of Approval: | |



DATE OF APPROVAL: 26 October 2016 Page: (2/ 3)

Director of Energy Safety

Certificate Number: ESV150300/06

Approval details

Addition of TRIDONIC models "LC 150W 200-1050mA sl EXC" and "LC 150W 200-1050mA IND sl EXC"

| | |
|------------|--|
| Model | LC 150W 200-1050mA sl EXC |
| Rated at | Input: 220-240 V, 158 W, 50/60 Hz Output: 400 Vdc, 150 W, 200-1050 mA |
| Trade Name | TRIDONIC |
| Comments | |

| | |
|------------|--|
| Model | LC 150W 200-1050mA IND sl EXC |
| Rated at | Input: 220-240 V, 158 W, 50/60 Hz Output: 400 Vdc, 150 W, 200-1050 mA |
| Trade Name | TRIDONIC |
| Comments | |

