

5 August 2016

43-47 Newton Rd  
Wetherill Park NSW 2164

Tridonic Australia Pty Ltd.

Dear Sir / Madam,

**APPROVAL OF NON-PRESCRIBED EQUIPMENT**

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria


Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact David Eddy on telephone (03) 9203 9700, or email [deddy@esv.vic.gov.au](mailto:deddy@esv.vic.gov.au)

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change of registered Address within 20 business days.

Yours sincerely



**DIRECTOR OF ENERGY SAFETY**

Ref: ESV150300/04

Certificate Number: ESV150300/04



# Certificate of Compliance

This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

**Registered Declarant:** Tridonic Australia Pty Ltd.  
43-47 Newton Rd  
Wetherill Park NSW 2164

**Authorised Marking:** ESV150300

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, may be clearly and indelibly marked with the marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification should be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

## ARTICLE DETAILS

Electrical Equipment:	Level 1 NP: Non-Prescribed constant current dimming LED driver for inbuilding
Relevant Standards:	AS/NZS 61347.2.13:2006; AS/NZS 61347.1:2002
Expiry Date:	13 May 2020
Conditions of Approval:	

## Approval details

constant current dimming LED driver for inbuilding
--

Model	LC 25W 100-500mA flexC lp EXC
Rated at	Input: 220-240 V, 29.2 W, 50/60 Hz Output: 60 Vdc, 25 W, 100-500 mA
Trade Name	TRIDONIC
Comments	

Model	LC 50W 350-1050mA flexC lp EXC
Rated at	Input: 220-240 V, 56.2 W, 50/60 Hz Output: 60 Vdc, 50.4 W, 350-1050 mA
Trade Name	TRIDONIC
Comments	

Model	LC 75W 350-1050mA flexC lp EXC
Rated at	Input: 220-240 V, 81.3 W, 50/60 Hz Output: 250 Vdc, 75 W, 350-1050 mA
Trade Name	TRIDONIC
Comments	

Model	LC 75W 900-1800mA flexC lp EXC
Rated at	Input: 220-240 V, 84.5 W, 50/60 Hz Output: 60 Vdc, 75 W, 900-1800 mA
Trade Name	TRIDONIC
Comments	

