

15 May 2019

2/7 Millner Ave  
Horsley Park NSW 2175

Tridonic Australia Pty Ltd.

Dear Sir / Madam,

**APPROVAL OF NON-PRESCRIBED EQUIPMENT**

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria


Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact Naveen Kapoor on telephone 92039774, or email [nkapoor@esv.vic.gov.au](mailto:nkapoor@esv.vic.gov.au)

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change of registered Address within 20 business days.

Yours sincerely



**DIRECTOR OF ENERGY SAFETY**

Ref: ESV190134/00

Certificate Number: ESV190134/00

# Certificate of Compliance

This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

**Registered Declarant:** Tridonic Australia Pty Ltd.  
2/7 Millner Ave  
Horsley Park NSW 2175

**Authorised Marking:** ESV190134

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, may be clearly and indelibly marked with the marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification should be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

## ARTICLE DETAILS

Electrical Equipment:	Level 1 NP: Non-Prescribed Constant current dimming LED driver: inbuilt type
Relevant Standards:	AS/NZS 61347.2.13:2013 and AS/NZS 61347.1:2013
Expiry Date:	15 May 2024
Conditions of Approval:	



Certificate Number: ESV190134/00



Creating a  
safer state with  
electricity and gas

## Approval details

Model	LC 50/250-400/140 o4a lp ADV
Rated at	Input: 220-240 V, 57 W, 50/60 Hz Output: 250 Vdc, 50 W, 250-400 mA
Trade Name	TRIDONIC
Comments	

Model	LC 50/600/83 o4a lp ADV
Rated at	Input: 220-240 V, 57 W, 50/60 Hz Output: 250 Vdc, 50 W, 600 mA
Trade Name	TRIDONIC
Comments	

Model	LC 75/250-400/220 o4a lp ADV
Rated at	Input: 220-240 V, 83 W, 50/60 Hz Output: 250 Vdc, 75 W, 250-400 mA
Trade Name	TRIDONIC
Comments	

A handwritten signature in black ink, appearing to read "P. J. Pearson".