

05 September 2014

F1 Palm Grove Business Park  
13-15 Forrester St  
Kingsgrove NSW 2208

Tridonic Australia Pty Ltd.

Attention: Phillip Lowe  
Dear Sir / Madam,

**APPROVAL OF NON-PRESCRIBED EQUIPMENT**

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria.

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact Jean Marie Ntahonkiriye on telephone (03) 9203 9700, or email [jntahonkiriye@esv.vic.gov.au](mailto:jntahonkiriye@esv.vic.gov.au)

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change of registered Address within 20 business days.

Yours faithfully

A handwritten signature in black ink, appearing to read "J. J. Flewson".

**DIRECTOR OF ENERGY SAFETY**

Ref: ESV140644/00

Certificate Number: ESV140644/00



# Certificate of Compliance



This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

**Registered Declarant:** Tridonic Australia Pty Ltd.  
F1 Palm Grove Business Park  
13-15 Forrester St  
Kingsgrove NSW 2208

**Authorised Marking:** ESV140644

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, may be clearly and indelibly marked with the marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification should be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

## ARTICLE DETAILS

Electrical Equipment:	Non Prescribed NP: Non-Prescribed Built-in type constant current controlgear for LED modules
Relevant Standards:	AS/NZS IEC 61347.2.13:2013 & AS/NZS 61347.1:2002
Expiry Date:	05/09/2019
Conditions of Approval:	



Certificate Number: ESV140644/00



A handwritten signature in black ink, appearing to read "P. J. Flewton".

DATE OF APPROVAL:05/09/2014 Page: (3/ 4)

Director of Energy Safety



Certificate Number: ESV140644/00



## Approval details

LCBI 10W PHASE-CUT/1-10V LP - BASIC

Model	LCBI 10W 180mA phase-cut/1-10V lp
Rated at	Input: 220-240V, 13W, 50/60Hz Output: 28-56V dc, 5-10W, 180mA
Trade Name	TRIDONIC
Comments	

Model	LCBI 10W 350mA phase-cut/1-10V lp
Rated at	Input: 220-240V, 13W, 50/60Hz Output: 14-28V dc, 5-10W, 350mA
Trade Name	TRIDONIC
Comments	

Model	LCBI 10W 500mA phase-cut/1-10V lp
Rated at	Input: 220-240V, 13W, 50/60Hz Output: 10-20V dc, 5-10W, 500mA
Trade Name	TRIDONIC
Comments	

A handwritten signature in black ink, appearing to read "P. J. Flewton".